

FIRE DEPARTMENT



(310) 253-5925

FAX (310) 253-5937

CHRIS SELLERS
Fire Chief

9770 CULVER BOULEVARD, CULVER CITY, CALIFORNIA 90232

MICHAEL BOWDEN
Fire Marshal

FIRE PREVENTION BUREAU

Special Permit Conditions
Vehicles Parked Inside a Film Studio

1. Vehicles to be inspected for and free of ignitable liquid leaks.
2. Vehicle should have less than a 1/4 tank of fuel.
3. Disconnect the negative battery cable.
4. Elephant (large stage) doors to be kept open while vehicles are on stage and stage is occupied.
5. All exits to be maintained unobstructed.
6. No smoking in building with signs posted
7. At least one 2A/10BC fire extinguisher needs to be immediately available.
8. Portable, temporary heat detectors to be in place and in operation when set is un-occupied.
9. Vehicles to be parked no closer than 20 feet to each other and no closer than 30 feet from building structure members.
10. No fueling of vehicles on set.

Print Name _____

Signature _____

Date _____

Culver City Employees take pride in effectively providing the highest levels of service to enrich the quality of life for the community by building on our tradition of more than seventy-five years of public service, by our present commitment, and by our dedication to meet the challenges of the future.