

FIRE DEPARTMENT



(310) 253-5925

FAX (310) 253-5937

9770 CULVER BOULEVARD, CULVER CITY, CALIFORNIA
90232-0507

CHRIS SELLERS
Fire Chief

MICHAEL BOWDEN
Fire Marshal

FIRE PREVENTION BUREAU

Fuel Truck Special Permit Conditions (Film Location)
Follow Los Angeles County Guidelines

1. This permit shall be with the fuel truck assigned to this permit.
2. Underwriters Laboratory approved pumps required.
3. Bonded fuel delivery hose with a hand actuated nozzle and no lock open device required.
4. An approved metal to metal grounding device must be used when dispensing flammable or combustible liquids.
5. A fire extinguisher of, minimum, 20BC rating shall be provided and immediately available to operator for the event of fire emergency.
6. Gravity dispensing of flammable or combustible liquids is not allowed.
7. Dispensing of flammable or combustible liquids is not allowed from fuel drums.
8. Emergency push-pull type emergency shut off switch is to be located on front of fuel truck.
9. Proper D.O.T. placards and warnings are required on vehicle, e.g., "Flammable, No Smoking within 50 feet."
10. Other –

Print Name _____

Signature _____ Date _____