

FIRE DEPARTMENT



(310) 253-5925

FAX (310) 253-5824

9770 CULVER BOULEVARD, CULVER CITY, CALIFORNIA 90232-0507

Chris Sellers
Fire Chief

MICHAEL BOWDEN
Fire Marshal

FIRE PREVENTION BUREAU

Tents & Canopies Special Permit Conditions

1. Compliance with 2007 California Fire Code Chapter 24 is required for tents over 200 sq ft. and canopies over 400 sq ft.
2. Material needs to be treated with fire retardant treatment and certified.
3. No Smoking posted.
4. No vehicles parked closer than 20 feet.
5. Exits to be clearly identified with signage, as required for clarity.
6. All permits are subject to revocation at discretion of CCFD.

Print Name _____ Date _____

Signature _____